

Map ID
Direction
Distance
Elevation

MAP FINDINGS

EDR ID Number
EPA ID Number

B31
WSW
< 1/8
0.110 mi.
579 ft.

CON ED YARD
1201 NEPTUNE AVE
BROOKLYN, NY
Site 3 of 7 in cluster B

NY Spills S118704801
N/A

Relative:
Higher

Actual:
1 ft.

SPILLS:

Name: CON ED YARD
Address: 1201 NEPTUNE AVE
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 1601732 / 2016-05-23
Facility ID: 1601732
Facility Type: ER
DER Facility ID: 61854
Site ID: 527109
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: C3
SWIS: 2401
Spill Date: 2016-05-20
Investigator: TJDEMEO
Referred To: Not reported
Reported to Dept: 2016-05-20
CID: Not reported
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2016-05-20
Spill Record Last Update: 2016-05-23
Spiller Name: MIKE BETO
Spiller Company: CON ED
Spiller Address: 1201 NEPTUNE AVE
Spiller Company: 999
Contact Name: MIKE BETO
DEC Memo: "5/20/16 TJD Teleconference with Paul Walsh at Con Ed ERT desk. Forklift was moving around a transformer in Con Edison yard when the unit tipped over spilling contents onto concrete which migrated to nearby drain. Con Edison is investigating discharge location to determine if outfall has been affected. Debris and sediment in catch basin have been affected by reported discharge. Guzzler will be dispatched to clean drain. DeMeo to inspect. NRC Report #1148294 5/20/16 TJD Site inspection. Estimated 40 gallons of non-pcb transformer oil spilled onto asphalt parking lot when straps broke while forklift was moving equipment in yard. Surface cleanup was completed by Con Edison personnel. Estimated 15 gallons entered yard zipper drain during dry weather. Con Edison retained the services of Clean Harbors Environmental for cleanup of drainage structures. Awaiting final cleanup documentation. 5/23/16 TJD Final EMIS report has been received (246246/4). Con Edison reports, Cleanup reported complete 1955, Catch Basins cleaned by Clean Venture using Vactor#137. Both basins Power-washed w/Safe wash, removed 800 gallons (25 Gallons Dielectric) transport to Cycle Chem reported by Adam Maugeri (96045) Sr Specialist EHS OPS. Documentation uploaded to DECDOCS. No further action required. Spill closed."

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

Remarks: "Spill to the concrete and catch basin. Clean up in progress."

All Materials:

Site ID: 527109
Operable Unit ID: 1275976
Operable Unit: 01
Material ID: 2280775
Material Code: 0016A
Material Name: non PCB oil
Case No.: Not reported
Material FA: Petroleum
Quantity: 40.00
Units: G
Recovered: Not reported
Oxygenate: Not reported